

Certification Report



Item Number **2060**

Manufacturing date 15.06.2017

Charge No. 07/17

Name

ANTIPOR 57 (BV)

Application

Concrete plasticizer for concrete acc. EN 934-2:T2

Range of dosage in mass-% of cement 0,2 - 0,9

State	liquid
Steadiness	homogeneous
Colour	dark brown
Active substances	lignin sulphonate

	Target	Measured	Stat. Determin.
Density in g/ml	1,09 - 1,15	1,136	
Dry substance in mass-%	27,1 - 29,9	28,2	
pH-value	3,5 - 5,5	5,1	
Water-soluble chloride content in mass-% max	0,1		0,020
Total value of chlor in mass-% max	0,1		
Alkali content (Na ₂ O-equivalent) in mass-% max	4		0,08

This document was automatically generated on 12.07.2017 and is valid without signature