

Certification Report



Item Number **2350**

Manufacturing date **16.01.2017**

Charge No. **01/17**

Name

ANTIPOR HydroCem-50 (VM)

Application

Viscosity modifying admixture acc. EN 934-2:T13

Range of dosage in mass-% of cement **0,2 - 2,1**

State **liquid**

Steadiness **homogeneous**

Colour **white**

Active substances **modified polycarboxylates**

	Target	Measured	Stat. Determin.
Density in g/ml	1,02 - 1,06	1,037	
Dry substance in mass-%	16,2 - 19,8	17,8	
pH-value	5,5 - 7,5	6,0	
Water-soluble chloride content in mass-% max	0,1		0,006
Total value of chlor in mass-% max	0,1		
Alkali content (Na ₂ O-equivalent) in mass-% max	4		0,49

This document was automatically generated on 24.03.2017 and is valid without signature